

Drinking Water Test Report

To:	Dairy Flat School
From:	Waste Management-Redvale
Sampling Date:	25 February 2026
Sampling Locations:	Staff Room (Figure 1), Health Room (Figure 2), Hall Kitchen (Figure 3)
Sampling Source:	Water Tap
Analytical Institution	Hill Laboratories

Analysis of Results

A summary of the February 2026 test results, along with comparisons to the October, November and December 2025 results and relevant New Zealand, WHO, and US EPA drinking-water standards, is provided in Table 1. The original Hill Labs report is attached at the end.



Figure 1. Staff Room



Figure 2. Health Room



Figure 3. Hall Kitchen

The February 2026 laboratory results indicate that the roof-collected rainwater supply is of good overall quality. No *Escherichia coli* was detected in any of the samples, confirming that the water was microbiologically safe at the time of sampling. Turbidity levels were very low (0.09–0.22 NTU), indicating clear water with minimal suspended particles and remaining well within the aesthetic guideline value (5 NTU) for drinking water.

The measured pH values (5.8–6.0) were slightly below the recommended aesthetic guideline range. This is not uncommon for roof-collected rainwater supplies due to their naturally low mineral content and the presence of dissolved atmospheric carbon dioxide. The very low alkalinity, hardness, electrical conductivity, and total dissolved solids further confirm that the water is extremely soft and has limited buffering capacity, which is characteristic of rainwater-derived drinking water.

While slightly acidic water may contribute to corrosion of plumbing materials and the potential leaching of metals from pipes or fittings, all measured metals and chemical parameters, including arsenic, copper, lead, nitrate, chloride, and sulphate, were well below the relevant drinking water guideline values.

Overall, the February 2026 results indicate that the roof-collected rainwater supply remains of good quality and suitable for drinking purposes. The results are generally consistent with previous monitoring conducted between October and December 2025, and all measured parameters complied with the relevant health-related drinking water standards.

Thanks,

Dr. Na Zhang (she/her)

Environmental Engineer Redvale Landfill – Operational and Technical Services

Drinking Water Test Report

WM New Zealand Limited
Landfill Access Road, RD4 Albany 0794
P.O. Box 228, Silverdale, Auckland 0944
M: +64 21 225 3226 E: NZhang@wm.nz
www.wm.nz



Drinking Water Test Report



WM New Zealand

Table 1. Summary of Tap Water Quality Results for October–December 2025 and February 2026, with Comparison to New Zealand, WHO, and US EPA Drinking Water Standards

Parameters	Sample Name: Lab Number:	Oct-25			Nov-25			Dec-25			Feb-26			Drinking Water Standards		
		Staff Room	Health Room	Hall Kitchen	Staff Room	Health Room	Hall Kitchen	Staff Room	Health Room	Hall Kitchen	Staff Room	Health Room	Hall Kitchen	NZ Maximum Acceptable Value (MAV) ^a	WHO Limit	US EPA Limit
Escherichia coli	MPN / 100mL	< 1	<1	< 1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Turbidity	NTU	0.37	0.41	0.12	0.20	0.21	0.11	0.230	0.277	0.128	0.22	0.19	0.09	≤5 (aesthetic) ^b	<5	<1 (recommended)
pH	pH Units	6.8	7.1	6.8	6.3	6.3	6.2	6.2	7.2	6.0	5.9	6.0	5.8	7.0–8.5 (aesthetic) ^b	6.5–8.5	6.5–8.5
Total Alkalinity	g/m3 as CaCO3	11	13.9	10.6	3.6	3.6	3.4	3.58	6.96	3.18	2.6	2.6	2.4	-	-	-
Free Carbon Dioxide	g/m3 at 25°C	3.3	2.1	3.4	4.0	3.8	4.2	4.9	<1.0	6.1	7	5.7	7.7	-	-	-
Total Hardness	g/m3 as CaCO3	14.5	16	14.5	2.3	2.5	3.2	1.79	1.79	2.20	2.70	2.60	2.90	≤200 (aesthetic) ^b	<500	<500
Electrical Conductivity (EC)	mS/m	6.4	7.5	6.3	1.6	1.8	1.6	1.0	1.7	1.0	2.6	2.8	2.7	-	-	-
Electrical Conductivity (EC)	µS/cm	64	75	63	16	18	16	10	17	10	26	28	27	-	<1500	<2500
Approx Total Dissolved Salts	g/m3	43	50	42	11	12	11	6.84	11.69	6.93	17	18	18	≤1000 (aesthetic) ^b	<1000	<500 (aesthetic) ^b
Total Arsenic	g/m3	< 0.0011	<0.0011	< 0.0011	<0.0011	<0.0011	<0.0011	<0.0011	<0.0011	<0.0011	<0.0011	<0.0011	<0.0011	<0.01	<0.01	<0.01
Total Boron	g/m3	< 0.053	<0.053	< 0.053	<0.053	<0.053	<0.053	<0.053	<0.053	<0.053	<0.053	<0.053	<0.053	<2.4	<2.4	-
Total Calcium	g/m3	4.4	4.6	4.4	0.57	0.60	0.91	0.438	0.43	0.613	0.36	0.36	0.49	-	-	-
Total Copper	g/m3	0.037	0.121	0.0038	0.061	0.141	0.0037	0.0694	0.128	0.00424	0.078	0.130	0.0044	<2	<2	<1.3
Total Iron	g/m3	< 0.021	0.023	< 0.021	<0.021	<0.021	<0.021	<0.021	<0.021	<0.021	<0.021	<0.021	<0.021	≤0.3 (aesthetic) ^b	<0.3	<0.3
Total Lead	g/m3	0.00062	0.00118	0.00028	0.00083	0.00088	0.00061	0.000966	0.001078	0.000604	0.001280	0.001330	0.00046	<0.01	<0.01	<0.015
Total Magnesium	g/m3	0.87	1.12	0.86	0.22	0.23	0.21	0.170	0.173	0.163	0.43	0.42	0.42	-	-	-
Total Manganese	g/m3	0.0023	0.0035	0.0012	0.00161	0.00157	0.00093	0.00196	0.00183	0.00151	0.00174	0.00198	0.0026	0.04 (Staining); ≤0.1(Taste)	<0.4	<0.05 (aesthetic) ^b
Total Potassium	g/m3	0.53	0.53	0.53	0.187	0.187	0.172	0.137	0.138	0.144	0.25	0.23	0.24	-	-	-
Total Sodium	g/m3	5.6	5.7	5.6	1.62	1.59	1.52	1.290	1.278	1.298	3.6	3.4	3.6	≤200 (aesthetic) ^b	<200	<20 (health advisory) ^c

Drinking Water Test Report



WM New Zealand

Total Zinc	g/m3	0.21	0.189	0.154	0.49	0.48	0.175	0.335	0.320	0.189	0.44	0.45	0.36	≤1.5 (aesthetic) ^b	<3	<5
Chloride	g/m3	9	9.6	9	2.6	2.6	2.7	2.53	2.29	2.16	6.0	5.6	6.0	≤250 (aesthetic) ^b	<250	<250
Nitrate-N	g/m3	0.07	0.07	0.08	0.09	0.09	0.11	0.147	0.126	0.171	0.15	0.15	0.16	<11.3	<11.3	<10
Sulphate	g/m3	4.3	4.6	4.3	0.8	0.8	0.8	0.76	0.77	0.69	1.2	1.2	1.2	≤250 (aesthetic) ^b	<250	<250

^a Taken from the 'Water Services (Drinking Water Standards for New Zealand) Regulations 2022'.

^b Taken from 'Aesthetic Value for Drinking Water Notice 2022' issued by the Water Services Regulator ("Taumata Arowai")

^c Refer to non-health-related parameters — things that affect the taste, smell, colour, or appearance of water but don't pose a health risk.

Certificate of Analysis

Page 1 of 4

Client:	Waste Management NZ Limited	Lab No:	4111982	DWAPV1
Contact:	Na Zhang C/- Waste Management NZ Limited PO Box 228 Silverdale Auckland 0944	Date Received:	26-Feb-2026	
		Date Reported:	03-Mar-2026	
		Quote No:	141146	
		Order No:	3867880	
		Client Reference:	DWSNZ Compliance – Roof/Rain	
		Add. Client Ref:	013 Dinking Water - DFS-SR	
		Submitted By:	Na Zhang	

Sample Type: Drinking Water for DWSNZ Compliance

Sample Name:		Drinking Water - DFS-SR 25-Feb-2026 12:40 pm	Aesthetic Values	Maximum Acceptable Values (MAV)
Lab Number:		4111982.1		
Routine Water + E.coli profile Kit				
Escherichia coli	MPN / 100mL	< 1	-	< 1
Routine Water Profile				
Turbidity	NTU	0.22	≤ 5	-
pH	pH Units	5.9	7.0 - 8.5	-
Total Alkalinity	g/m ³ as CaCO ₃	2.6	-	-
Free Carbon Dioxide	g/m ³ at 25°C	7.0	-	-
Total Hardness	g/m ³ as CaCO ₃	2.7	≤ 200	-
Electrical Conductivity (EC)	mS/m	2.6	-	-
Electrical Conductivity (EC)	µS/cm	26	-	-
Approx Total Dissolved Salts	g/m ³	17	≤ 1000	-
Total Arsenic	g/m ³	< 0.0011	-	0.01
Total Boron	g/m ³	< 0.053	-	2.4
Total Calcium	g/m ³	0.36	-	-
Total Copper	g/m ³	0.078	≤ 1	2
Total Iron	g/m ³	< 0.021	≤ 0.3	-
Total Lead	g/m ³	0.00128	-	0.01
Total Magnesium	g/m ³	0.43	-	-
Total Manganese	g/m ³	0.00174	≤ 0.04 (Staining) ≤ 0.10 (Taste)	0.4
Total Potassium	g/m ³	0.25	-	-
Total Sodium	g/m ³	3.6	≤ 200	-
Total Zinc	g/m ³	0.44	≤ 1.5	-
Chloride	g/m ³	6.0	≤ 250	-
Nitrate-N	g/m ³	0.15	-	11.3
Sulphate	g/m ³	1.2	≤ 250	-

Note: The Maximum Acceptable Values (MAV) are taken from the 'Water Services (Drinking Water Standards for New Zealand) Regulations 2022', published under the authority of the New Zealand Government-2022. Copies of this publication are available from: <https://www.legislation.govt.nz/regulation/public/2022/0168/latest/whole.html>

The standards set limits for the concentration of determinands in drinking water. The Maximum Acceptable Values (MAVs) for any determinand must not be exceeded at any time.

The Aesthetic Values are taken the publication, 'Aesthetic Values for Drinking Water Notice 2022' issued by the Water Services Regulator ("Taumata Arowai"). Aesthetic values specify or provide minimum or maximum values for substances and other characteristics that relate to the acceptability of drinking water to consumers (such as appearance, taste or odour).

Note that the units: g/m³ are the same as mg/L and ppm.



This Laboratory is accredited by International Accreditation New Zealand (IANZ), which represents New Zealand in the International Laboratory Accreditation Cooperation (ILAC). Through the ILAC Mutual Recognition Arrangement (ILAC-MRA) this accreditation is internationally recognised. The tests reported herein have been performed in accordance with the terms of accreditation, with the exception of tests marked * or any comments and interpretations, which are not accredited.

pH/Alkalinity and Corrosiveness Assessment

The pH of a water sample is a measure of its acidity or basicity. Waters with a low pH can be corrosive and those with a high pH can promote scale formation in pipes and hot water cylinders.

The guideline level for pH in drinking water is 7.0-8.5. Below this range the water will be corrosive and may cause problems with disinfection if such treatment is used.

The alkalinity of a water is a measure of its acid neutralising capacity and is usually related to the concentration of carbonate, bicarbonate and hydroxide. Low alkalinities (25 g/m^3) promote corrosion and high alkalinities can cause problems with scale formation in metal pipes and tanks.

With the pH and alkalinity levels found it is likely this water will be quite corrosive towards metal piping and fixtures.

Hardness/Total Dissolved Salts Assessment

The water contains a very low amount of dissolved solids and would be regarded as being very soft.

Nitrate Assessment

Nitrate-nitrogen at elevated levels is considered undesirable in natural waters as this element can cause a health disorder called methaemaglobinaemia. Very young infants (less than six months old) are especially vulnerable. The 'Water Services (Drinking Water Standards for New Zealand) Regulations 2022' sets a maximum permissible level of 11.3 g/m^3 as Nitrate-nitrogen (50 g/m^3 as Nitrate).

Nitrate-nitrogen was detected in this water but at such a low level to not be of concern.

Boron Assessment

Boron may be present in natural waters and if present at high concentrations can be toxic to plants.

Boron was not detected in this water.

Metals Assessment

Iron and manganese are two problem elements that commonly occur in natural waters. These elements may cause unsightly stains and produce a brown/black precipitate. Iron is not toxic but manganese, at concentrations above 0.5 g/m^3 , may adversely affect health. At concentrations below this it may cause stains on clothing and sanitary ware.

Iron was not detected in the water

Manganese was found in this water at a low level.

Treatment to remove iron and/or manganese should not be necessary.

Bacteriological Tests

The Drinking Water Standards for NZ state that there should be no Escherichia coli (E coli) in water used for human consumption. The presence of these organisms would indicate that other pathogens of faecal origin may be present. Results obtained for Total Coliforms are only significant if the sample has not also been tested for E coli.

Escherichia coli was not detected in this sample.

Final Assessment

The parameter pH did NOT meet the guidelines laid down in the 'Water Services (Drinking Water Standards for New Zealand) Regulations 2022' and the 'Aesthetic Values for Drinking Water Notice 2022' issued by the Water Services Regulator ("Taumata Arowai") for water which is suitable for drinking purposes.

Summary of Methods

The following table(s) gives a brief description of the methods used to conduct the analyses for this job. The detection limits given below are those attainable in a relatively simple matrix. Detection limits may be higher for individual samples should insufficient sample be available, or if the matrix requires that dilutions be performed during analysis. A detection limit range indicates the lowest and highest detection limits in the associated suite of analytes. A full listing of compounds and detection limits are available from the laboratory upon request. Unless otherwise indicated, analyses were performed at Hill Labs, 28 Duke Street, Frankton, Hamilton 3204.

Sample Type: Drinking Water for DWSNZ Compliance			
Test	Method Description	Default Detection Limit	Sample No
Routine Water Profile		-	1
Filtration, Unpreserved	Sample filtration through 0.45µm membrane filter.	-	1
Total Digestion	Nitric acid digestion. APHA 3030 E (modified) : Online Edition.	-	1
Turbidity	Analysis by Turbidity meter. APHA 2130 B (modified) : Online Edition.	0.05 NTU	1
pH	pH meter. APHA 4500-H ⁺ B (modified) : Online Edition. Note: It is not possible to achieve the APHA Maximum Storage Recommendation for this test (15 min) when samples are analysed upon receipt at the laboratory, and not in the field. Samples and Standards are analysed at an equivalent laboratory temperature (typically 18 to 22 °C). Temperature compensation is used.	0.1 pH Units	1
Total Alkalinity	Titration to pH 4.5 (M-alkalinity), autotitrator. APHA 2320 B (modified for Alkalinity <20) : Online Edition.	1.0 g/m ³ as CaCO ₃	1
Free Carbon Dioxide	Calculation: from alkalinity and pH, valid where TDS is not >500 mg/L and alkalinity is almost entirely due to hydroxides, carbonates or bicarbonates. APHA 4500-CO ₂ D : Online Edition.	1.0 g/m ³ at 25°C	1
Total Hardness	Calculation from Total Calcium and Total Magnesium. APHA 2340 B : Online Edition.	1.0 g/m ³ as CaCO ₃	1
Electrical Conductivity (EC)	Conductivity meter, 25°C. APHA 2510 B : Online Edition.	0.1 mS/m	1
Electrical Conductivity (EC)	Conductivity meter, 25°C. APHA 2510 B : Online Edition.	1 µS/cm	1
Approx Total Dissolved Salts	Calculation: from Electrical Conductivity.	2 g/m ³	1
Total Arsenic	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.0011 g/m ³	1
Total Boron	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.053 g/m ³	1
Total Calcium	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.053 g/m ³	1
Total Copper	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.00053 g/m ³	1
Total Iron	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.021 g/m ³	1
Total Lead	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.00011 g/m ³	1
Total Magnesium	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.021 g/m ³	1
Total Manganese	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.00053 g/m ³	1
Total Potassium	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.053 g/m ³	1
Total Sodium	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.021 g/m ³	1
Total Zinc	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.0011 g/m ³	1
Chloride	Filtered sample. Ion Chromatography. APHA 4110 B (modified) : Online Edition.	0.5 g/m ³	1
Nitrate-N	Filtered sample. Ion Chromatography. APHA 4110 B (modified) : Online Edition.	0.05 g/m ³	1
Sulphate	Filtered sample. Ion Chromatography. APHA 4110 B (modified) : Online Edition.	0.5 g/m ³	1
Escherichia coli	MPN count using Colilert (Incubated at 35°C for 24 hours) and 97 wells. APHA 9223 B : Online Edition.	1 MPN / 100mL	1

These samples were collected by yourselves (or your agent) and analysed as received at the laboratory.

Testing was completed between 26-Feb-2026 and 03-Mar-2026. For completion dates of individual analyses please contact the laboratory.

Samples are held at the laboratory after reporting for a length of time based on the stability of the samples and analytes being tested (considering any preservation used), and the storage space available. Once the storage period is completed, the samples are discarded unless otherwise agreed with the customer. Extended storage times may incur additional charges.

This certificate of analysis must not be reproduced, except in full, without the written consent of the signatory.



Kim Harrison MSc
Client Services Manager - Environmental

Certificate of Analysis

Page 1 of 4

Client:	Waste Management NZ Limited	Lab No:	4111989	DWAPV1
Contact:	Na Zhang C/- Waste Management NZ Limited PO Box 228 Silverdale Auckland 0944	Date Received:	26-Feb-2026	
		Date Reported:	03-Mar-2026	
		Quote No:	141146	
		Order No:	3867883	
		Client Reference:	014 Drinking Water - DFS- HR	
		Add. Client Ref:	DWSNZ Compliance – Roof/Rain	
		Submitted By:	Na Zhang	

Sample Type: Drinking Water for DWSNZ Compliance

Sample Name:		Drinking water-DFS-HR 25-Feb-2026 1:00 pm	Aesthetic Values	Maximum Acceptable Values (MAV)
Lab Number:		4111989.1		
Routine Water + E.coli profile Kit				
Escherichia coli	MPN / 100mL	< 1	-	< 1
Routine Water Profile				
Turbidity	NTU	0.19	≤ 5	-
pH	pH Units	6.0	7.0 - 8.5	-
Total Alkalinity	g/m ³ as CaCO ₃	2.6	-	-
Free Carbon Dioxide	g/m ³ at 25°C	5.7	-	-
Total Hardness	g/m ³ as CaCO ₃	2.6	≤ 200	-
Electrical Conductivity (EC)	mS/m	2.8	-	-
Electrical Conductivity (EC)	µS/cm	28	-	-
Approx Total Dissolved Salts	g/m ³	18	≤ 1000	-
Total Arsenic	g/m ³	< 0.0011	-	0.01
Total Boron	g/m ³	< 0.053	-	2.4
Total Calcium	g/m ³	0.36	-	-
Total Copper	g/m ³	0.130	≤ 1	2
Total Iron	g/m ³	< 0.021	≤ 0.3	-
Total Lead	g/m ³	0.00133	-	0.01
Total Magnesium	g/m ³	0.42	-	-
Total Manganese	g/m ³	0.00198	≤ 0.04 (Staining) ≤ 0.10 (Taste)	0.4
Total Potassium	g/m ³	0.23	-	-
Total Sodium	g/m ³	3.4	≤ 200	-
Total Zinc	g/m ³	0.45	≤ 1.5	-
Chloride	g/m ³	5.6	≤ 250	-
Nitrate-N	g/m ³	0.15	-	11.3
Sulphate	g/m ³	1.2	≤ 250	-

Note: The Maximum Acceptable Values (MAV) are taken from the 'Water Services (Drinking Water Standards for New Zealand) Regulations 2022', published under the authority of the New Zealand Government-2022. Copies of this publication are available from: <https://www.legislation.govt.nz/regulation/public/2022/0168/latest/whole.html>

The standards set limits for the concentration of determinands in drinking water. The Maximum Acceptable Values (MAVs) for any determinand must not be exceeded at any time.

The Aesthetic Values are taken the publication, 'Aesthetic Values for Drinking Water Notice 2022' issued by the Water Services Regulator ("Taumata Arowai"). Aesthetic values specify or provide minimum or maximum values for substances and other characteristics that relate to the acceptability of drinking water to consumers (such as appearance, taste or odour).

Note that the units: g/m³ are the same as mg/L and ppm.



This Laboratory is accredited by International Accreditation New Zealand (IANZ), which represents New Zealand in the International Laboratory Accreditation Cooperation (ILAC). Through the ILAC Mutual Recognition Arrangement (ILAC-MRA) this accreditation is internationally recognised. The tests reported herein have been performed in accordance with the terms of accreditation, with the exception of tests marked * or any comments and interpretations, which are not accredited.

pH/Alkalinity and Corrosiveness Assessment

The pH of a water sample is a measure of its acidity or basicity. Waters with a low pH can be corrosive and those with a high pH can promote scale formation in pipes and hot water cylinders.

The guideline level for pH in drinking water is 7.0-8.5. Below this range the water will be corrosive and may cause problems with disinfection if such treatment is used.

The alkalinity of a water is a measure of its acid neutralising capacity and is usually related to the concentration of carbonate, bicarbonate and hydroxide. Low alkalinities (25 g/m^3) promote corrosion and high alkalinities can cause problems with scale formation in metal pipes and tanks.

With the pH and alkalinity levels found it is likely this water will be quite corrosive towards metal piping and fixtures.

Hardness/Total Dissolved Salts Assessment

The water contains a very low amount of dissolved solids and would be regarded as being very soft.

Nitrate Assessment

Nitrate-nitrogen at elevated levels is considered undesirable in natural waters as this element can cause a health disorder called methaemaglobinaemia. Very young infants (less than six months old) are especially vulnerable. The 'Water Services (Drinking Water Standards for New Zealand) Regulations 2022' sets a maximum permissible level of 11.3 g/m^3 as Nitrate-nitrogen (50 g/m^3 as Nitrate).

Nitrate-nitrogen was detected in this water but at such a low level to not be of concern.

Boron Assessment

Boron may be present in natural waters and if present at high concentrations can be toxic to plants.

Boron was not detected in this water.

Metals Assessment

Iron and manganese are two problem elements that commonly occur in natural waters. These elements may cause unsightly stains and produce a brown/black precipitate. Iron is not toxic but manganese, at concentrations above 0.5 g/m^3 , may adversely affect health. At concentrations below this it may cause stains on clothing and sanitary ware.

Iron was not detected in the water

Manganese was found in this water at a low level.

Treatment to remove iron and/or manganese should not be necessary.

Bacteriological Tests

The Drinking Water Standards for NZ state that there should be no Escherichia coli (E coli) in water used for human consumption. The presence of these organisms would indicate that other pathogens of faecal origin may be present. Results obtained for Total Coliforms are only significant if the sample has not also been tested for E coli.

Escherichia coli was not detected in this sample.

Final Assessment

The parameter pH did NOT meet the guidelines laid down in the 'Water Services (Drinking Water Standards for New Zealand) Regulations 2022' and the 'Aesthetic Values for Drinking Water Notice 2022' issued by the Water Services Regulator ("Taumata Arowai") for water which is suitable for drinking purposes.

Summary of Methods

The following table(s) gives a brief description of the methods used to conduct the analyses for this job. The detection limits given below are those attainable in a relatively simple matrix. Detection limits may be higher for individual samples should insufficient sample be available, or if the matrix requires that dilutions be performed during analysis. A detection limit range indicates the lowest and highest detection limits in the associated suite of analytes. A full listing of compounds and detection limits are available from the laboratory upon request. Unless otherwise indicated, analyses were performed at Hill Labs, 28 Duke Street, Frankton, Hamilton 3204.

Sample Type: Drinking Water for DWSNZ Compliance			
Test	Method Description	Default Detection Limit	Sample No
Routine Water Profile		-	1
Filtration, Unpreserved	Sample filtration through 0.45µm membrane filter.	-	1
Total Digestion	Nitric acid digestion. APHA 3030 E (modified) : Online Edition.	-	1
Turbidity	Analysis by Turbidity meter. APHA 2130 B (modified) : Online Edition.	0.05 NTU	1
pH	pH meter. APHA 4500-H ⁺ B (modified) : Online Edition. Note: It is not possible to achieve the APHA Maximum Storage Recommendation for this test (15 min) when samples are analysed upon receipt at the laboratory, and not in the field. Samples and Standards are analysed at an equivalent laboratory temperature (typically 18 to 22 °C). Temperature compensation is used.	0.1 pH Units	1
Total Alkalinity	Titration to pH 4.5 (M-alkalinity), autotitrator. APHA 2320 B (modified for Alkalinity <20) : Online Edition.	1.0 g/m ³ as CaCO ₃	1
Free Carbon Dioxide	Calculation: from alkalinity and pH, valid where TDS is not >500 mg/L and alkalinity is almost entirely due to hydroxides, carbonates or bicarbonates. APHA 4500-CO ₂ D : Online Edition.	1.0 g/m ³ at 25°C	1
Total Hardness	Calculation from Total Calcium and Total Magnesium. APHA 2340 B : Online Edition.	1.0 g/m ³ as CaCO ₃	1
Electrical Conductivity (EC)	Conductivity meter, 25°C. APHA 2510 B : Online Edition.	0.1 mS/m	1
Electrical Conductivity (EC)	Conductivity meter, 25°C. APHA 2510 B : Online Edition.	1 µS/cm	1
Approx Total Dissolved Salts	Calculation: from Electrical Conductivity.	2 g/m ³	1
Total Arsenic	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.0011 g/m ³	1
Total Boron	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.053 g/m ³	1
Total Calcium	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.053 g/m ³	1
Total Copper	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.00053 g/m ³	1
Total Iron	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.021 g/m ³	1
Total Lead	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.00011 g/m ³	1
Total Magnesium	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.021 g/m ³	1
Total Manganese	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.00053 g/m ³	1
Total Potassium	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.053 g/m ³	1
Total Sodium	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.021 g/m ³	1
Total Zinc	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.0011 g/m ³	1
Chloride	Filtered sample. Ion Chromatography. APHA 4110 B (modified) : Online Edition.	0.5 g/m ³	1
Nitrate-N	Filtered sample. Ion Chromatography. APHA 4110 B (modified) : Online Edition.	0.05 g/m ³	1
Sulphate	Filtered sample. Ion Chromatography. APHA 4110 B (modified) : Online Edition.	0.5 g/m ³	1
Escherichia coli	MPN count using Colilert (Incubated at 35°C for 24 hours) and 97 wells. APHA 9223 B : Online Edition.	1 MPN / 100mL	1

These samples were collected by yourselves (or your agent) and analysed as received at the laboratory.

Testing was completed between 26-Feb-2026 and 03-Mar-2026. For completion dates of individual analyses please contact the laboratory.

Samples are held at the laboratory after reporting for a length of time based on the stability of the samples and analytes being tested (considering any preservation used), and the storage space available. Once the storage period is completed, the samples are discarded unless otherwise agreed with the customer. Extended storage times may incur additional charges.

This certificate of analysis must not be reproduced, except in full, without the written consent of the signatory.



Kim Harrison MSc
Client Services Manager - Environmental

Certificate of Analysis

Page 1 of 5

Client:	Waste Management NZ Limited	Lab No:	4111983	DWAPV1
Contact:	Na Zhang C/- Waste Management NZ Limited PO Box 228 Silverdale Auckland 0944	Date Received:	26-Feb-2026	
		Date Reported:	03-Mar-2026	
		Quote No:	141146	
		Order No:	3867886	
		Client Reference:	DWSNZ Compliance – Roof/Rain	
		Add. Client Ref:	015 Drinking Water-DFS-HK	
		Submitted By:	Na Zhang	

Sample Type: Drinking Water for DWSNZ Compliance

Sample Name:		Drinking Water-DFS-HK 25-Feb-2026 1:15 pm		Aesthetic Values	Maximum Acceptable Values (MAV)
Lab Number:		4111983.1			
Routine Water + E.coli profile Kit					
Escherichia coli	MPN / 100mL	< 1 #1		-	< 1
Routine Water Profile					
Turbidity	NTU	0.09		≤ 5	-
pH	pH Units	5.8		7.0 - 8.5	-
Total Alkalinity	g/m ³ as CaCO ₃	2.4		-	-
Free Carbon Dioxide	g/m ³ at 25°C	7.7		-	-
Total Hardness	g/m ³ as CaCO ₃	2.9		≤ 200	-
Electrical Conductivity (EC)	mS/m	2.7		-	-
Electrical Conductivity (EC)	µS/cm	27		-	-
Approx Total Dissolved Salts	g/m ³	18		≤ 1000	-
Total Arsenic	g/m ³	< 0.0011		-	0.01
Total Boron	g/m ³	< 0.053		-	2.4
Total Calcium	g/m ³	0.49		-	-
Total Copper	g/m ³	0.0044		≤ 1	2
Total Iron	g/m ³	< 0.021		≤ 0.3	-
Total Lead	g/m ³	0.00046		-	0.01
Total Magnesium	g/m ³	0.42		-	-
Total Manganese	g/m ³	0.0026		≤ 0.04 (Staining) ≤ 0.10 (Taste)	0.4
Total Potassium	g/m ³	0.24		-	-
Total Sodium	g/m ³	3.6		≤ 200	-
Total Zinc	g/m ³	0.36		≤ 1.5	-
Chloride	g/m ³	6.0		≤ 250	-
Nitrate-N	g/m ³	0.16		-	11.3
Sulphate	g/m ³	1.2		≤ 250	-

Note: The Maximum Acceptable Values (MAV) are taken from the 'Water Services (Drinking Water Standards for New Zealand) Regulations 2022', published under the authority of the New Zealand Government-2022. Copies of this publication are available from: <https://www.legislation.govt.nz/regulation/public/2022/0168/latest/whole.html>

The standards set limits for the concentration of determinands in drinking water. The Maximum Acceptable Values (MAVs) for any determinand must not be exceeded at any time.

The Aesthetic Values are taken the publication, 'Aesthetic Values for Drinking Water Notice 2022' issued by the Water Services Regulator ("Taumata Arowai"). Aesthetic values specify or provide minimum or maximum values for substances and other characteristics that relate to the acceptability of drinking water to consumers (such as appearance, taste or odour).

Note that the units: g/m³ are the same as mg/L and ppm.



This Laboratory is accredited by International Accreditation New Zealand (IANZ), which represents New Zealand in the International Laboratory Accreditation Cooperation (ILAC). Through the ILAC Mutual Recognition Arrangement (ILAC-MRA) this accreditation is internationally recognised. The tests reported herein have been performed in accordance with the terms of accreditation, with the exception of tests marked * or any comments and interpretations, which are not accredited.

Analyst's Comments

#1 Please interpret this result with caution as the sample was > 10 °C on receipt at the lab. The sample temperature is recommended by the laboratory's reference methods to be less than 10 °C on receipt at the laboratory (but not frozen). However, it is acknowledged that samples that are transported quickly to the laboratory after sampling, may not have been cooled to this temperature.

pH/Alkalinity and Corrosiveness Assessment

The pH of a water sample is a measure of its acidity or basicity. Waters with a low pH can be corrosive and those with a high pH can promote scale formation in pipes and hot water cylinders.

The guideline level for pH in drinking water is 7.0-8.5. Below this range the water will be corrosive and may cause problems with disinfection if such treatment is used.

The alkalinity of a water is a measure of its acid neutralising capacity and is usually related to the concentration of carbonate, bicarbonate and hydroxide. Low alkalinities (25 g/m^3) promote corrosion and high alkalinities can cause problems with scale formation in metal pipes and tanks.

With the pH and alkalinity levels found it is likely this water will be quite corrosive towards metal piping and fixtures.

Hardness/Total Dissolved Salts Assessment

The water contains a very low amount of dissolved solids and would be regarded as being very soft.

Nitrate Assessment

Nitrate-nitrogen at elevated levels is considered undesirable in natural waters as this element can cause a health disorder called methaemaglobinaemia. Very young infants (less than six months old) are especially vulnerable. The 'Water Services (Drinking Water Standards for New Zealand) Regulations 2022' sets a maximum permissible level of 11.3 g/m^3 as Nitrate-nitrogen (50 g/m^3 as Nitrate).

Nitrate-nitrogen was detected in this water but at such a low level to not be of concern.

Boron Assessment

Boron may be present in natural waters and if present at high concentrations can be toxic to plants.

Boron was not detected in this water.

Metals Assessment

Iron and manganese are two problem elements that commonly occur in natural waters. These elements may cause unsightly stains and produce a brown/black precipitate. Iron is not toxic but manganese, at concentrations above 0.5 g/m^3 , may adversely affect health. At concentrations below this it may cause stains on clothing and sanitary ware.

Iron was not detected in the water

Manganese was found in this water at a low level.

Treatment to remove iron and/or manganese should not be necessary.

Bacteriological Tests

The Drinking Water Standards for NZ state that there should be no Escherichia coli (E coli) in water used for human consumption. The presence of these organisms would indicate that other pathogens of faecal origin may be present. Results obtained for Total Coliforms are only significant if the sample has not also been tested for E coli.

Escherichia coli was not detected in this sample.

Final Assessment

The parameter pH did NOT meet the guidelines laid down in the 'Water Services (Drinking Water Standards for New Zealand) Regulations 2022' and the 'Aesthetic Values for Drinking Water Notice 2022' issued by the Water Services Regulator ("Taumata Arowai") for water which is suitable for drinking purposes.

Summary of Methods

The following table(s) gives a brief description of the methods used to conduct the analyses for this job. The detection limits given below are those attainable in a relatively simple matrix. Detection limits may be higher for individual samples should insufficient sample be available, or if the matrix requires that dilutions be performed during analysis. A detection limit range indicates the lowest and highest detection limits in the associated suite of analytes. A full listing of compounds and detection limits are available from the laboratory upon request. Unless otherwise indicated, analyses were performed at Hill Labs, 28 Duke Street, Frankton, Hamilton 3204.

Sample Type: Drinking Water for DWSNZ Compliance			
Test	Method Description	Default Detection Limit	Sample No
Routine Water Profile		-	1
Filtration, Unpreserved	Sample filtration through 0.45µm membrane filter.	-	1
Total Digestion	Nitric acid digestion. APHA 3030 E (modified) : Online Edition.	-	1
Turbidity	Analysis by Turbidity meter. APHA 2130 B (modified) : Online Edition.	0.05 NTU	1
pH	pH meter. APHA 4500-H ⁺ B (modified) : Online Edition. Note: It is not possible to achieve the APHA Maximum Storage Recommendation for this test (15 min) when samples are analysed upon receipt at the laboratory, and not in the field. Samples and Standards are analysed at an equivalent laboratory temperature (typically 18 to 22 °C). Temperature compensation is used.	0.1 pH Units	1
Total Alkalinity	Titration to pH 4.5 (M-alkalinity), autotitrator. APHA 2320 B (modified for Alkalinity <20) : Online Edition.	1.0 g/m ³ as CaCO ₃	1
Free Carbon Dioxide	Calculation: from alkalinity and pH, valid where TDS is not >500 mg/L and alkalinity is almost entirely due to hydroxides, carbonates or bicarbonates. APHA 4500-CO ₂ D : Online Edition.	1.0 g/m ³ at 25°C	1
Total Hardness	Calculation from Total Calcium and Total Magnesium. APHA 2340 B : Online Edition.	1.0 g/m ³ as CaCO ₃	1
Electrical Conductivity (EC)	Conductivity meter, 25°C. APHA 2510 B : Online Edition.	0.1 mS/m	1
Electrical Conductivity (EC)	Conductivity meter, 25°C. APHA 2510 B : Online Edition.	1 µS/cm	1
Approx Total Dissolved Salts	Calculation: from Electrical Conductivity.	2 g/m ³	1
Total Arsenic	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.0011 g/m ³	1
Total Boron	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.053 g/m ³	1
Total Calcium	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.053 g/m ³	1
Total Copper	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.00053 g/m ³	1
Total Iron	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.021 g/m ³	1
Total Lead	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.00011 g/m ³	1
Total Magnesium	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.021 g/m ³	1
Total Manganese	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.00053 g/m ³	1
Total Potassium	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.053 g/m ³	1
Total Sodium	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.021 g/m ³	1
Total Zinc	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.0011 g/m ³	1
Chloride	Filtered sample. Ion Chromatography. APHA 4110 B (modified) : Online Edition.	0.5 g/m ³	1
Nitrate-N	Filtered sample. Ion Chromatography. APHA 4110 B (modified) : Online Edition.	0.05 g/m ³	1
Sulphate	Filtered sample. Ion Chromatography. APHA 4110 B (modified) : Online Edition.	0.5 g/m ³	1
Escherichia coli	MPN count using Colilert (Incubated at 35°C for 24 hours) and 97 wells. APHA 9223 B : Online Edition.	1 MPN / 100mL	1

These samples were collected by yourselves (or your agent) and analysed as received at the laboratory.

Testing was completed between 26-Feb-2026 and 03-Mar-2026. For completion dates of individual analyses please contact the laboratory.

Samples are held at the laboratory after reporting for a length of time based on the stability of the samples and analytes being tested (considering any preservation used), and the storage space available. Once the storage period is completed, the samples are discarded unless otherwise agreed with the customer. Extended storage times may incur additional charges.

This certificate of analysis must not be reproduced, except in full, without the written consent of the signatory.



Kim Harrison MSc
Client Services Manager - Environmental